



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-253 / RD-245

Date: 17.11.2025

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Vision Fire & Safety Engineering** having their registration office at **8 & 12, Shree Sagar CHS, Sai Baba Nagar, Mira Rd (East), Thane 401107** and their contact details are Office Number: 9967772821 and Email ID: visionfire.eng@gmail.com with PAN registration No. AAMFV5309D and GST No. 27AAMFV5309D1Z3 to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Fire Fighting and Sprinkler System:** **Class A**
- 2. Detection and Fire Suppression System:** **Class D**

M/s. Vision Fire & Safety Engineering shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **17.11.2025 to 16.11.2027**

CLASSO
GEORGE
FERNANDES
Digitally signed by
CLASSO GEORGE
FERNANDES
Date: 2025.11.18 10:18:53
+05'30'

License Agency Digital Sign

SANTOSH
SHRIDHAR
WARICK
Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2025.11.18
21:26:09 +05'30'

(S S Warick)
Director
MF&ES, Mumbai

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

This license has been issued under the provisions in section 9 (5) and section 18 (2) and is valid in all Local Authorities as defined in section 2 (7) & Planning Authorities as defined in section 2(12) of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be :-
 - a) Non-transferable
 - b) Valid for two year from the date of issue, unless suspended or cancelled earlier.
 - c) Renewable, if so desired, before expiry of the licence.
2. Changes, if any. In respect of the –
 - a) Partners, Directors or Members
 - b) Address of the office of the License AgencyShall be forthwith reported to the Directorate of Maharashtra Fire Service.
3. The Licensed Agency shall always keep the work executed or being executed, open for inspection by the Director, or any Fire Officer authorized by the Director.
4. The Licensed Agency shall issue a certificate in Form “A” to the client in respect of the works executed by them and shall issue a six monthly certificate in Form –“B”, in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient conditions at all times.
5. Refer Circular issued by this Office vide No. MFS/51/2022/236, dated 15.02.2022
6. **M/s. Vision Fire & Safety Engineering (Partnership) has paid amount of Rs. 40,000/- (Rs. Forty Thousand Only) vide UTR No. HDFCN52025092794992252, dated 27.09.2025 towards registration fees.**



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in



Expertise with Responsibility

**Supply and Installation of fire Hydrant system, fire detection and sprinkler system
Annual Maintenance contract (AMC) of fire fighting system, fire extinguishers**

Address: Shop No. 8 & 12, Shree Sagar Tower CHS, Behind New Tulsi Tower, Sai baba Nagar, Opp. New Indian Oil Petrol Pump,
Mira Road (East), Thane -401 107, T: 022 -28131166/ 8591610158,E: visionfire.eng@gmail.com

**Ref. No.: VFSE /306B - Jan/2026
Licence No.1: MFS-LA/2019/RF- 253
Licence No.2: MFS-LA/2019/RD- 245**

Date: 08.01.2026

FORM B

{{(See Section 3(3) and rule 4(2))}}

**Six monthly certificates to be given in January and July by owner or the occupation
for compliance of the fire Prevention and Life Safety Measures.**

CERTIFICATE

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely:-

Description of Building or Premises:

M/s. St John International school

**G+3 Floor Manor Rd, near Shakti Udyog, Industrial Area, Vevoor,
Palghar, Maharashtra 401404**

I/We further certify that these installations in the above mentioned building is maintained in good repair and efficient condition during the period ending **01st July 2025 to 31st December 2025**, as required under the provisions of Maharashtra Fire Prevention and Life Safety Measured Act, 2006 (Mah.III of 2007).

The details of the inspection of installations carried out by me/us are mentioned in the report appended herewith.

Place: Mira Road (E)

Date: 08.01.2026

CLASSO

FERNANDES

Digitally signed by
CLASSO FERNANDES
Date: 2026.01.08
15:18:42 +05'30'

Vision Fire & Safety Engineering
Shop No.8 Shree Sagar CHS Ltd.,
Sai Baba Nagar, Mira Road (E)
Thane – 401107.

Date: 08.01.2026

The following fire fighting facilities are tested & found ok at

M/s St John International school G+3 Floor Manor Rd, near Shakti Udyog, Industrial Area, Vevoor, Palghar, Maharashtra 401404

Fire Hydrant System:

- Hydrant Main Pump - 1 No.
- Hydrant Jockey Pump -1 No
- Booster Pump – 2 No.
- Electric control panel -1
- S. S. Single Hydrant Valve – 15 Nos.
- Hose reel drum with thermoplast pipe with shut off nozzle – 12 Nos.
- Single door hose box – 12 Nos.
- Canvas hose pipe with male female coupling – 12 Nos.
- Branch Pipe – 12 Nos.
- Two Way Breeching – 2 Nos.
- Sprinkler system
- ABC type Fire Extinguishers

Fire Alarm System:

- Fire Alarm Control Panel -1 No.
- Manual Call Points – 8 Nos.

Yours faithfully,

For Vision Fire & Safety Engineering

CLASSO

FERNANDES

Digitally signed by

CLASSO

FERNANDES

Date: 2026.01.08

15:18:55 +05'30'

(Authorized Signatory)